

P.O. Box 554 | 2665 ZN Bleiswijk Brandpuntlaan Zuid 16 | 2665 NZ Bleiswijk The Netherlands +31 88 3473 723 nederland@efectis.com

# **CLASSIFICATION**

# CLASSIFICATION OF REACTION TO FIRE PERFORMANCE IN ACCORDANCE WITH EN 13501-1:2007+A1:2009

Classification no. 2015-Efectis-R000408 [Rev.1]

Sponsor Avery Dennison

Willem Einthovenstraat 11 2342 BH OEGSTGEEST THE NETHERLANDS

Product name Avery Dennison® 5300 Blockout Films

Prepared by Efectis Nederland BV

Notified body no. 1234

Author(s) C.C.M. Steinhage B.Sc.

E.O. van der Laan M.Sc.

Project number ENL-14-000837

Date of issue May 2015

Number of pages 5

All rights reserved

No part of this publication may be reproduced and/or published without the previous written consent of Efectis Nederland. Submitting the report for inspection to parties who have a direct interest is permitted.





#### 1. INTRODUCTION

#### 1.1 PRODUCT NAME

This classification report defines the classification assigned to **Avery Dennison® 5300 Blockout Films** in accordance with the procedures given in EN 13501-1:2007+A1:2009.

#### 1.2 REVISION INFORMATION

Sponsor address corrected.

Full reference to Avery Dennison® included in the product name.

Original date of issue: April 2015

#### 2. DETAILS OF CLASSIFIED PRODUCT

#### 2.1 GENERAL

The product, Avery Dennison® 5300 Blockout Films, is defined as a wall covering.

#### 2.2 MANUFACTURER

Avery Dennison Willem Einthovenstraat 11 2342 BH OEGSTGEEST THE NETHERLANDS

## 2.3 PRODUCT DESCRIPTION

According to the sponsor the product is composed of:

Face film: 100 μm premium, cast vinyl film

Adhesive: 125 µm permanent, clear, acrylic based

Backing paper: polycoated kraft paper, 140 g/m²

Two types:

- 5301: white finish and a black adhesive side
- 5303: black finish and a white adhesive side

The product has a total thickness of approx. 225  $\mu m$  and a mass per unit area of approx. 180 g/m<sup>2</sup> (measured on the product).

See the 'Product data sheet' in the test reports.



# 3. REPORTS, RESULTS AND CRITERIA IN SUPPORT OF THIS CLASSIFICATION

# 3.1 REPORTS

Name of Laboratories	Name of sponsor	Report ref. no.	Test method
Efectis Nederland BV THE NETHERLANDS	Avery Dennison Graphics & Reflective Solutions THE NETHERLANDS	2015-Efectis-R000406 2015-Efectis-R000407	EN ISO 11925-2:2010 EN 13823:2014

# 3.2 TEST RESULTS

Test method and test number	Parameter		No. tests	Results	
				Continuous parameter - mean (m)	Compliance with parameters
EN ISO 11925-2					
surface flame	Fs ≤150 mm		6	31	-
impingement	Ignition of filter paper			-	Compliant
Edge flame	Fs ≤150 mm		6	17	-
impingement	Ignition of filter	paper	O	-	Compliant
EN 13823					
Black finish	FIGRA <sub>0.2MJ</sub>	[W/s]		115	-
	FIGRA <sub>0.4MJ</sub>	[W/s]		19	-
	THR <sub>600s</sub>	[MJ]	3	0.8	-
	LFS < edge			-	Compliant
	SMOGRA	$[m^2/s^2]$		20.1	-
	TSP <sub>600s</sub>	[m <sup>2</sup> ]		49	-
	Flaming debris - flaming ≤ 10 s - flaming > 10 s			-	Compliant Compliant
White finish	FIGRA <sub>0.2MJ</sub>	[W/s]	1	88	-
	FIGRA <sub>0.4MJ</sub>	[W/s]		0	-
	THR <sub>600s</sub>	[MJ]		0.8	-
	LFS < edge			-	Compliant
	SMOGRA	$[m^2/s^2]$		11.1	-
	TSP <sub>600s</sub>	$[m^2]$		42	-
	Flaming debris - flaming ≤ 10 s - flaming > 10 s			-	Compliant Compliant



#### 3.3 CLASSIFICATION CRITERIA

Fire classification of construction products and building elements Excluding floorings and linear pipe thermal insulation products							
Classification criteria							
Class Test method(s)	В	С	D				
<b>EN ISO 11925-2</b> Exposure = 30 s	$F_s \le 150$ mm within 60 s Ignition of the paper in EN ISO 11925-2 results in a d2 classification.						
EN 13823	$\begin{array}{l} FIGRA_{0.2~MJ} \leq 120~W/s \\ LFS < edge~of~specimen \\ THR_{600s} \leq 7.5~MJ \end{array}$	FIGRA <sub>0.4 MJ</sub> $\leq$ 250 W/s LFS $<$ edge of specimen THR <sub>600s</sub> $\leq$ 15 MJ	FIGRA <sub>0.4 MJ</sub> ≤ 750 W/s				
Additional classification							
Smoke production	$S1 = SMOGRA \le 30 \text{ m}^2/\text{s}^2 \text{ and } TSP_{600s} \le 50 \text{ m}^2;$ $S2 = SMOGRA \le 180 \text{ m}^2/\text{s}^2 \text{ and } TSP_{600s} \le 200 \text{ m}^2;$ S3 = not s1 or s2						
Flaming Droplets/particles	d1 = no flaming drople	no flaming droplets/ particles persisting longer than 10 s in EN 13823 within 600 s;					

# 4. CLASSIFICATION AND FIELD OF APPLICATION

# 4.1 REFERENCE OF CLASSIFICATION

This classification has been carried out in accordance with clause 11 of EN 13501-1:2007+ A1:2009.

## 4.2 CLASSIFICATION

The product, Avery Dennison® 5300 Blockout Films, in relation to its reaction to fire behaviour is classified:

В

The additional classification in relation to smoke production is:

s1

The additional classification in relation to flaming droplets / particles is:

d0

Reaction to fire classification: B - s1, d0



#### 4.3 FIELD OF APPLICATION

This classification is valid for the following product parameters:

**Thickness** 

 Face film 100 µm 125 µm Adhesive

Surface density Approx. 180 g/m<sup>2</sup>

Other aspects White and black finish colour only

This classification is valid for the following end use applications:

Substrate Non-combustible

(class A1 according to EN 13238:2010)

Air gap Including air gap

Methods and means of fixing Glued, using the products adhesive

Joints Vertical joints only

Other aspects of end use

conditions

Wall covering

# 4.4 DURATION OF THE VALIDITY OF THIS CLASSIFICATION REPORT

There are no limitations in time on the validity of this report.

#### LIMITATIONS 5.

This classification document does not represent type approval or certification of the product.

C.C.M. Steinhage B.Sc. Project leader reaction to fire

E.O. van der Laan M.Sc. Project leader reaction to fire