

P.O. Box 554 | 2665 ZN Bleiswijk Brandpuntlaan Zuid 16 | 2665 NZ Bleiswijk The Netherlands +31 88 3473 723 nederland@efectis.com

CLASSIFICATION

CLASSIFICATION OF REACTION TO FIRE PERFORMANCE IN ACCORDANCE WITH EN 13501-1:2007+A1:2009

Classification no. 2015-Efectis-R001026

Sponsor Avery Dennison

Graphics & Reflective Solutions

P.O. Box 28 2300 AA LEIDEN THE NETHERLANDS

Product name Avery Dennison®, MPI[™] 1104 Cast series

Prepared by Efectis Nederland BV

Notified body no. 1234

Author(s) C.C.M. Steinhage B.Sc.

E.O. van der Laan M.Sc.

Project number ENL-15-000723

Date of issue August 2015

Number of pages 5

All rights reserved.

No part of this publication may be reproduced and/or published without the previous written consent of Efectis Nederland. Submitting the report for inspection to parties who have a direct interest is permitted.



In case this report was drafted on instructions, the rights and obligations of contracting parties are subject to either the Standard Conditions of Efectis Nederland or the relevant agreement concluded between the contracting parties.

© 2015 Efectis Nederland BV Page 1 / 5



1. INTRODUCTION

This classification report defines the classification assigned to Avery Dennison®, MPITM 1104 Cast series in accordance with the procedures given in EN 13501-1:2007+A1:2009.

2. DETAILS OF CLASSIFIED PRODUCT

2.1 GENERAL

The product, Avery Dennison®, MPITM 1104 Cast series, is defined as a wall covering.

2.2 MANUFACTURER

Avery Dennison Graphics & Reflective Solutions P.O. Box 28 2300 AA LEIDEN THE NETHERLANDS

2.3 PRODUCT DESCRIPTION

According to the sponsor the product is from inside out composed of:

Film: 50 µm gloss white cast vinyl

Adhesive: 30 µm repositionable permanent, grey tie coat, acrylic based

Backing paper

MPI 1104 Staflat linerMPI 1104 EA Easy Apply liner

The product has a total thickness of approx. 80 μm and a mass per unit area of approx. 115 g/m² (measured on the product).

See also Appendix 'Product data sheet' in the test reports.

3. REPORTS, RESULTS AND CRITERIA IN SUPPORT OF THIS CLASSIFICATION

3.1 REPORTS

Name of Laboratories	Name of sponsor	Report ref. no.	Test method
Efectis Nederland BV THE NETHERLANDS	Avery Dennison Graphics & Reflective Solutions THE NETHERLANDS	2015-Efectis-R001024 2015-Efectis-R001025	EN ISO 11925-2:2010 EN 13823:2014



3.2 TEST RESULTS

			Results		
Test method and test number	Paramete	er	tests par	Continuous parameter - mean (m)	Compliance with parameters
EN ISO 11925-2					
surface flame impingement	Fs ≤150 mm		6	29	-
	Ignition of filter	paper	0	-	Compliant
Edge flame		6	15	-	
Impingement	Ignition of filter	paper	0	-	Compliant
EN 13823					
	FIGRA _{0.2MJ}	[W/s]		56	-
	FIGRA _{0.4MJ} [\	[W/s]		0	-
	THR _{600s}	[LM]		0.5	-
	LFS < edge		0	-	Compliant
	SMOGRA	$[m^2/s^2]$	3	12	-
	TSP _{600s}	[m ²]		44	-
	Flaming debris - flaming ≤ 10 s - flaming > 10 s			-	Compliant Compliant

3.3 CLASSIFICATION CRITERIA

Fire classification of construction products and building elements Excluding floorings and linear pipe thermal insulation products							
Classification criteria							
Class Test method(s)	В	С	D				
EN ISO 11925-2 Exposure = 30 s	$F_s \le 150$ mm within 60 s Ignition of the paper in EN ISO 11925-2 results in a d2 classification.						
EN 13823	FIGRA _{0.2 MJ} \leq 120 W/s LFS $<$ edge of specimen THR _{600s} \leq 7.5 MJ	FIGRA _{0.4 MJ} \leq 250 W/s LFS $<$ edge of specimen THR _{600s} \leq 15 MJ	FIGRA _{0.4 MJ} ≤ 750 W /s				
Additional classification							
Smoke production	$s1 = SMOGRA \le 30 \text{ m}^2/\text{s}^2 \text{ and } TSP_{600s} \le 50 \text{ m}^2$; $s2 = SMOGRA \le 180 \text{ m}^2/\text{s}^2 \text{ and } TSP_{600s} \le 200 \text{ m}^2$; s3 = not s1 or s2						
Flaming Droplets/particles	d0 = no flaming droplets/ particles in EN 13823 within 600 s; d1 = no flaming droplets/ particles persisting longer than 10 s in EN 13823 within 600 s; d2 = not d0 or d1.						



4. CLASSIFICATION AND FIELD OF APPLICATION

4.1 REFERENCE OF CLASSIFICATION

This classification has been carried out in accordance with clause 11 of EN 13501-1:2007+ A1:2009.

4.2 CLASSIFICATION

The product, Avery Dennison®, MPITM 1104 Cast series, in relation to its reaction to fire behaviour is classified:

В

The additional classification in relation to smoke production is:

S1

The additional classification in relation to flaming droplets / particles is:

d0

Reaction to fire classification: B - s1, d0

4.3 FIELD OF APPLICATION

This classification is valid for the following product parameters:

Thickness

Film 50 μmAdhesive 30 μm

Surface density 115 g/m²

This classification is valid for the following end use applications:

Substrate Non-combustible

(class A1 according to EN 13238:2010)

Air gap 40 mm

Methods and means of fixing Glued, using the products adhesive

Joints Including joints

Other aspects of end use Wall covering

conditions

4.4 DURATION OF THE VALIDITY OF THIS CLASSIFICATION REPORT

There are no limitations in time on the validity of this report.



CLASSIFICATION



LIMITATIONS

This classification document does not represent type approval or certification of the product.

C.C.M. Steinhage B.Sc. Project leader reaction to fire E.O. van der Laan M.Sc. Project leader reaction to fire