

P.O. Box 554 | 2665 ZN Bleiswijk Brandpuntlaan Zuid 16 | 2665 NZ Bleiswijk The Netherlands +31 88 3473 723 nederland@efectis.com

CLASSIFICATION

CLASSIFICATION OF REACTION TO FIRE PERFORMANCE IN ACCORDANCE WITH EN 13501-1:2007+A1:2009

Classification no. 2016-Efectis-R000630

Sponsor **Avery Dennison**

Willem Einthovenstraat 11 2342 BH OEGSTGEEST THE NETHERLANDS

Product name MPI 1105 and MPI 1105 EA RS

Prepared by **Efectis Nederland BV**

Notified body no. 1234

Author(s) C.C.M. Steinhage B.Sc.

A.J. Lock

Project number ENL-16-000471

Date of issue June 2016

Number of pages 5

No part of this publication may be reproduced and/or published without the previous written consent of Efectis Nederland. Submitting the report for inspection to parties who have a direct interest is permitted.





INTRODUCTION

This classification report defines the classification assigned to MPI 1105 and MPI 1105 EA RS in accordance with the procedures given in EN 13501-1:2007+A1:2009.

2. DETAILS OF CLASSIFIED PRODUCT

2.1 GENERAL

The product, MPI 1105 and MPI 1105 EA RS, is defined as a wall covering.

2.2 MANUFACTURER

Avery Dennison Graphics & Reflective Solutions P.O. Box 28 2300 AA LEIDEN THE NETHERLANDS

2.3 PRODUCT DESCRIPTION

According to the sponsor the product is from inside out composed of:

Film: 50 μm, gloss white cast vinyl

Colour: white

Adhesive: 30 µm, permanent, acrylic based with grey tie coat and long term

removability properties

Backing paper: Two sided PE coated StaFlat[™] paper, 155 g/m²

See appendix 'Product data sheet' in the test reports for more detailed specifications.

The product has a total thickness of 50 μ m and a mass per unit area of approx. 120 g/m² (measured on the product).

3. REPORTS, RESULTS AND CRITERIA IN SUPPORT OF THIS CLASSIFICATION

3.1 REPORTS

Name of Laboratories	Name of sponsor	Report ref. no.	Test method
Efectis Nederland BV THE NETHERLANDS	Avery Dennison Graphics & Reflective Solutions THE NETHERLANDS	2016-Efectis-R000628 2016-Efectis-R000629	EN ISO 11925-2:2010 EN 13823:2014



3.2 TEST RESULTS

Test method and test number			Results	
	Parameter	No. tests	Continuous parameter - mean (m)	Compliance with parameters
EN ISO 11925-2				
surface flame impingement	Fs ≤150 mm	6	25	-
	Ignition of filter paper		-	Compliant
Edge flame Impingement	Fs ≤150 mm	6	17	-
	Ignition of filter paper		-	Compliant
EN 13823				
MPI 1105 EA RS	FIGRA _{0.2MJ} [W/	s]	24	-
	FIGRA _{0.4MJ} [W/	s]	0	-
	THR _{600s} [M.	J]	0.6	-
	LFS < edge		-	Compliant
	SMOGRA [m²/s	3	6.7	-
	TSP _{600s} [m	2]	41	-
	Flaming debris - flaming ≤ 10 s - flaming > 10 s		-	Compliant Compliant
MPI 1105	FIGRA _{0.2MJ} [W/	s]	33	-
	FIGRA _{0.4MJ} [W/s]		0	-
	THR _{600s} [MJ]		0.5	-
	LFS < edge		-	Compliant
	SMOGRA [m ² /s ²]	1	9.8	-
	TSP _{600s} [m ²]		38	-
	Flaming debris - flaming ≤ 10 s - flaming > 10 s		-	Compliant Compliant



3.3 CLASSIFICATION CRITERIA

Fire classification of construction products and building elements Excluding floorings and linear pipe thermal insulation products						
Classification criteria						
Class Test method(s)	В	С	D			
EN ISO 11925-2 Exposure = 30 s	$F_s \le 150$ mm within 60 s Ignition of the paper in EN ISO 11925-2 results in a d2 classification.					
EN 13823	$\begin{array}{l} FIGRA_{0.2MJ} \leq 120 \;W/s \\ LFS < edge \;of \;specimen \\ THR_{600s} \leq 7.5 \;MJ \end{array}$	FIGRA _{0.4 MJ} \leq 250 W/s LFS $<$ edge of specimen THR _{600s} \leq 15 MJ	FIGRA _{0.4 MJ} ≤ 750 W/s			
Additional classification						
Smoke production	$S1 = SMOGRA \le 30 \text{ m}^2/\text{s}^2 \text{ and } TSP_{600s} \le 50 \text{ m}^2;$ $S2 = SMOGRA \le 180 \text{ m}^2/\text{s}^2 \text{ and } TSP_{600s} \le 200 \text{ m}^2;$ S3 = not s1 or s2					
Flaming Droplets/particles	d1 = no flaming drople	EN 13823 within 600 s;				

4. CLASSIFICATION AND FIELD OF APPLICATION

4.1 REFERENCE OF CLASSIFICATION

This classification has been carried out in accordance with clause 11 of EN 13501-1:2007+ A1:2009.

4.2 CLASSIFICATION

The product, MPI 1105 and MPI 1105 EA RS, in relation to its reaction to fire behaviour is classified:

В

The additional classification in relation to smoke production is:

s1

The additional classification in relation to flaming droplets \prime particles is:

d0

Reaction to fire classification: B - s1, d0





4.3 FIELD OF APPLICATION

This classification is valid for the following product parameters:

Thickness

Film
 Adhesive
 50 μm
 30 μm

Surface density Approx. 120 g/m² (measured on the product)

Other properties Colour: white

This classification is valid for the following end use applications:

Substrate Non-combustible

(class A1/A2 according to EN 13238:2010)

Air gap Including air gap

Methods and means of fixing Using the adhesive of the product

Joints Vertical only

Other aspects of end use

conditions

Wall covering

4.4 DURATION OF THE VALIDITY OF THIS CLASSIFICATION REPORT

There are no limitations in time on the validity of this report.

5. LIMITATIONS

This classification document does not represent type approval or certification of the product.

C.C.M. Steinhage B.Sc.

Project leader reaction to fire

A.J. Lock

Project leader reaction to fire