

Efectis Nederland P.O. Box 554 | 2665 ZN Bleiswijk Brandpuntlaan Zuid 16 | 2665 NZ Bleiswijk The Netherlands +31 88 3473 723 nederland@efectis.com

CLASSIFICATION

CLASSIFICATION OF REACTION TO FIRE PERFORMANCE IN ACCORDANCE WITH EN 13501-1:2007+A1:2009

Classification no. 2018-Efectis-R001988

Sponsor Avery Dennison

> Willem Einthovenstraat 11 2342 BH OEGSTGEEST THE NETHERLANDS

Product name Avery Dennison® MPI™ 3000/3020 Opaque Series

Prepared by Efectis Nederland BV

1234 Notified body no.

Author(s) C.C.M. Steinhage B.Sc.

A.J. Lock

Project number ENL-18-000808

Date of issue November 2018

Number of pages 6

All rights reserved.

No part of this publication may be reproduced and/or published without the previous written consent of Efectis Nederland. Submitting the report for inspection to parties who have a direct interest is permitted.







1. INTRODUCTION

This classification report defines the classification assigned to **Avery Dennison® MPI™ 3000/3020 Opaque Series** in accordance with the procedures given in EN 13501-1:2007+A1:2009.

2. DETAILS OF CLASSIFIED PRODUCT

2.1 GENERAL

The product, **Avery Dennison® MPI™ 3000/3020 Opaque Series**, is defined as a multipurpose vinyl.

2.2 MANUFACTURER

Avery Dennison Graphics & Reflective Solutions P.O. Box 28 2300 AA LEIDEN THE NETHERLANDS

2.3 PRODUCT DESCRIPTION

According to the sponsor the product is composed of: Type:

- MPI 3002/3003 Opaque:
 - Face film: 95 μm white gloss PVC film;
 - Adhesive: Permanent, grey acrylic based;
- MPI 3022/3023 Opaque:
 - Face film: 95 micron white matt PVC film;
 - Adhesive: Removable, grey acrylic based;
- Backing paper: Clay coated kraft paper, 125 g/m².

The product has a mass per unit area of approx. 140 g/m² (measured on the product). See also Appendix, 'Product data sheet' in the test reports.

3. STANDARDS, REPORTS, RESULTS AND CRITERIA IN SUPPORT OF THIS CLASSIFICATION

3.1 APPLICABLE (PRODUCT) STANDARDS

EN ISO 11925-2:2010	Reaction to fire tests - Ignitability of products subjected to direct impingement of flame - Part 2: Single-flame source test		
EN 13823:2010+A1:2014	Reaction to fire tests for building products - Building products, excluding floorings exposed to the thermal attack by a single burning item		
EN 13501-1:2007 +A1:2009	Fire classification of construction products and building elements Part 1: Classification using data from reaction to fire tests		



3.2 REPORTS

Name of Laboratories	Name of sponsor	Report ref. no.	Test method
Efectis Nederland BV THE NETHERLANDS	Avery Dennison Graphics & Reflective Solutions THE NETHERLANDS	2018-Efectis-R001986 2018-Efectis-R001987	EN ISO 11925-2:2010 EN 13823:2014

3.3 TEST RESULTS

			Results	
Test method and test number	Parameter	No. tests	Continuous parameter – maximum	Compliance with parameters
EN ISO 11925-2				
MPI 3002				
surface flame	Fs ≤150 mm	6	20	-
impingement	Ignition of filter paper	6	-	Compliant
Edge flame	Fs ≤150 mm		20	-
Impingement	Ignition of filter paper	6	-	Compliant

	d Parameter		No. tests	Results	
Test method and test number				Continuous parameter – mean (m)	Compliance with parameters
EN 13823					
MPI 3002	FIGRA _{0.2MJ}	[W/s]		28	-
	FIGRA _{0.4MJ}	[W/s]		0	-
	THR _{600s}	[MJ]		0.6	-
	LFS < edge			-	Compliant
	SMOGRA	$[m^2/s^2]$	3	23	-
	TSP _{600s}	[m ²]		36	-
	Flaming debris - flaming ≤ 10 s - flaming > 10 s			-	Compliant Compliant
MPI 3003	FIGRA _{0.2MJ}	[W/s]		0	-
	FIGRA _{0.4MJ}	[W/s]		0	-
	THR _{600s}	[MJ]		0.8	-
	LFS < edge			-	Compliant
	SMOGRA	$[m^2/s^2]$	1	16	-
	TSP _{600s}	[m ²]		22	-
	Flaming debris - flaming ≤ 10 s - flaming > 10 s			- -	Compliant Compliant



MPI 3022	FIGRA _{0.2MJ}	[W/s]		0	-
	FIGRA _{0.4MJ}	[W/s]		0	-
	THR _{600s}	[MJ]		0.6	-
	LFS < edge			-	Compliant
	SMOGRA	$[m^2/s^2]$	1	16.9	-
	TSP _{600s}	[m ²]		38	-
	Flaming debris - flaming ≤ 10 s - flaming > 10 s			-	Compliant Compliant
MPI 3023	FIGRA _{0.2MJ}	[W/s]		0	-
	FIGRA _{0.4MJ}	[W/s]		0	-
	THR _{600s}	[MJ]		0.0	-
	LFS < edge		1	-	Compliant
	SMOGRA	$[m^2/s^2]$		16.2	-
	TSP _{600s}	[m ²]		37	-
	Flaming debris - flaming ≤ 10 s - flaming > 10 s			-	Compliant Compliant

3.4 CLASSIFICATION CRITERIA

Fire classification of construction products and building elements Excluding floorings and linear pipe thermal insulation products						
Classification crit	Classification criteria					
Class Test method(s)	В	С	D			
EN ISO 11925-2 Exposure = 30 s	$F_s \le 150$ mm within 60 s Ignition of the paper in EN ISO 11925-2 results in a d2 classification.					
EN 13823	FIGRA _{0.2 MJ} \leq 120 W/s LFS $<$ edge of specimen THR _{600s} \leq 7.5 MJ	FIGRA _{0.4 MJ} \leq 250 W/s LFS $<$ edge of specimen THR _{600s} \leq 15 MJ	FIGRA _{0.4 MJ} ≤ 750 W/s			
Additional classification						
Smoke production	s1 = SMOGRA ≤ 30 m ² /s ² and TSP _{600s} ≤ 50 m ² ; s2 = SMOGRA ≤ 180 m ² /s ² and TSP _{600s} ≤ 200 m ² ; s3 = not s1 or s2					
Flaming Droplets/particles	 d0 = no flaming droplets/ particles in EN 13823 within 600 s; d1 = no flaming droplets/ particles persisting longer than 10 s in EN 13823 within 600 s; d2 = not d0 or d1. 					





4. CLASSIFICATION AND FIELD OF APPLICATION

4.1 REFERENCE OF CLASSIFICATION

This classification has been carried out in accordance with clause 11 of EN 13501-1:2007+ A1:2009.

4.2 CLASSIFICATION

The product, **Avery Dennison® MPI™ 3000/3020 Opaque Series**, in relation to its reaction to fire behaviour is classified:

В

The additional classification in relation to smoke production is:

S

The additional classification in relation to flaming droplets / particles is:

d0

Reaction to fire classification: B - s1, d0

4.3 FIELD OF APPLICATION

This classification is valid for the following product parameters:

Thickness

• Film 95 μm

Surface density Approx.140 g/m²

Other properties Colour: white

This classification is valid for the following end use applications:

Substrate Non-combustible

(class A1/A2 according to EN 13238:2010)

Air gap Including air gap

Methods and means of fixing Glued using the products adhesive

Joints Vertical only

Other aspects of end use

conditions

Used as multi-purpose vinyl

4.4 DURATION OF THE VALIDITY OF THIS CLASSIFICATION REPORT

There are no limitations in time on the validity of this report.



Efectis Nederland 2018-Efectis-R001988 November 2018 Avery Dennison

CLASSIFICATION

5. LIMITATIONS

This classification document does not represent type approval or certification of the product.

C.C.M. Steinhage B.Sc. Project leader reaction to fire

A.J. Lock Project leader reaction to fire