

Efectis Nederland P.O. Box 554 | 2665 ZN Bleiswijk Brandpuntlaan Zuid 16 | 2665 NZ Bleiswijk The Netherlands +31 88 3473 723 nederland@efectis.com

CLASSIFICATION

CLASSIFICATION OF REACTION TO FIRE PERFORMANCE IN ACCORDANCE WITH EN 13501-1:2007+A1:2009

Classification no. 2018-Efectis-R001991

Sponsor Avery Dennison Graphics & Reflective Solutions

> P.O. Box 28 2300 AA LEIDEN THE NETHERLANDS

Product name Avery Dennison® MPI™ 3151

Promotional Translucent White

Prepared by Efectis Nederland BV

Notified body no. 1234

Author(s) C.C.M. Steinhage B.Sc.

A.J. Lock

Project number ENL-18-000808

Date of issue November 2018

Number of pages 5

All rights reserved.

No part of this publication may be reproduced and/or published without the previous written consent of Efectis Nederland. Submitting the report for inspection to parties who have a direct interest is permitted.







1. INTRODUCTION

This classification report defines the classification assigned to **Avery Dennison® MPI™ 3151 Promotional Translucent White** in accordance with the procedures given in EN 13501-1:2007+A1:2009.

2. DETAILS OF CLASSIFIED PRODUCT

2.1 GENERAL

The product, **Avery Dennison® MPI™ 3151 Promotional Translucent White**, is defined as a multi-purpose vinyl.

2.2 MANUFACTURER

Avery Dennison Graphics & Reflective Solutions P.O. Box 28 2300 AA LEIDEN THE NETHERLANDS

2.3 PRODUCT DESCRIPTION

According to the sponsor the product is composed of:

Face film: 80 μm, white monomeric translucent PVC film;

Adhesive: 15 µm, removable, acrylic based

Backing paper: kraft paper, 125 g/m².

The product has a total thickness of approx. 95 μ m and a mass per unit area of approx. 116 g/m² (measured on the product).

See also Appendix 'Product data sheet' in the test reports.

STANDARDS, REPORTS, RESULTS AND CRITERIA IN SUPPORT OF THIS CLASSIFICATION

3.1 APPLICABLE (PRODUCT) STANDARDS

EN ISO 11925-2:2010	Reaction to fire tests - Ignitability of products subjected to direct impingement of flame - Part 2: Single-flame source test
EN 13823:2010+A1:2014	Reaction to fire tests for building products - Building products, excluding floorings exposed to the thermal attack by a single burning item
EN 13501-1:2007 +A1:2009	Fire classification of construction products and building elements Part 1: Classification using data from reaction to fire tests



3.2 REPORTS

Name of Laboratories	Name of sponsor	Report ref. no.	Test method
Efectis Nederland BV THE NETHERLANDS	Avery Dennison Graphics & Reflective Solutions THE NETHERLANDS	2018-Efectis-R001989 2018-Efectis-R0018990	EN ISO 11925-2:2010 EN 13823:2014

3.3 TEST RESULTS

	Parameter	No. tests	Results	
Test method and test number			Continuous parameter – maximum	Compliance with parameters
EN ISO 11925-2				
surface flame	Fs ≤150 mm	6	20	-
impingement	Ignition of filter paper		-	Compliant
Edge flame	Fs ≤150 mm	6	20	-
Impingement	Ignition of filter paper	6	-	Compliant

	Parameter		No. tests	Results	
Test method and test number				Continuous parameter – mean (m)	Compliance with parameters
EN 13823					
	FIGRA _{0.2MJ}	[W/s]		87	-
	FIGRA _{0.4MJ}	[W/s]		0	-
	THR _{600s}	[MJ]		0.6	-
	LFS < edge			-	Compliant
	SMOGRA	$[m^2/s^2]$	3	26	-
	TSP _{600s}	[m ²]		38	-
	Flaming debris - flaming ≤ 10 s - flaming > 10 s			- -	Compliant Compliant



3.4 CLASSIFICATION CRITERIA

Fire classification of construction products and building elements Excluding floorings and linear pipe thermal insulation products					
Classification crit	Classification criteria				
Class Test method(s)	В	С	D		
EN ISO 11925-2 Exposure = 30 s	$F_s \le 150$ mm within 60 s Ignition of the paper in EN ISO 11925-2 results in a d2 classification.				
EN 13823	FIGRA _{0.2 MJ} \leq 120 W/s LFS $<$ edge of specimen THR _{600s} \leq 7.5 MJ	FIGRA _{0.4 MJ} \leq 250 W/s LFS < edge of specimen THR _{600s} \leq 15 MJ	FIGRA _{0.4 MJ} ≤ 750 W/s		
Additional classification					
Smoke production	s1 = SMOGRA \leq 30 m ² /s ² and TSP _{600s} \leq 50 m ² ; s2 = SMOGRA \leq 180 m ² /s ² and TSP _{600s} \leq 200 m ² ; s3 = not s1 or s2				
Flaming Droplets/particles	 d0 = no flaming droplets/ particles in EN 13823 within 600 s; d1 = no flaming droplets/ particles persisting longer than 10 s in EN 13823 within 600 s; d2 = not d0 or d1. 				

4. CLASSIFICATION AND FIELD OF APPLICATION

4.1 REFERENCE OF CLASSIFICATION

This classification has been carried out in accordance with clause 11 of EN 13501-1:2007+ A1:2009.

4.2 CLASSIFICATION

The product, **Avery Dennison® MPI™ 3151 Promotional Translucent White**, in relation to its reaction to fire behaviour is classified:

В

The additional classification in relation to smoke production is:

S1

The additional classification in relation to flaming droplets / particles is:

d0

Reaction to fire classification: B - s1, d0



Efectis Nederland 2018-Efectis-R001991 November 2018 Avery Dennison

CLASSIFICATION

4.3 FIELD OF APPLICATION

This classification is valid for the following product parameters:

Thickness

 Face film 80 µm 15 µm Adhesive

116 g/m² Surface density

Other properties Colour: white

This classification is valid for the following end use applications:

Substrate Non-combustible

(class A1/A2 according to EN 13238:2010)

Air gap Including air gap

Glued using the products adhesive Methods and means of fixing

Joints Vertical only

Other aspects of end use

conditions

Used as a multi-purpose vinyl

4.4 DURATION OF THE VALIDITY OF THIS CLASSIFICATION REPORT

There are no limitations in time on the validity of this report.

LIMITATIONS 5.

This classification document does not represent type approval or certification of the product.

C.C.M. Steinhage B.Sc.

Project leader reaction to fire

A.J. Lock

Project leader reaction to fire