

P.O. Box 554 | 2665 ZN Bleiswijk Brandpuntlaan Zuid 16 | 2665 NZ Bleiswijk The Netherlands +31 88 3473 723 nederland@efectis.com

CLASSIFICATION

CLASSIFICATION OF REACTION TO FIRE PERFORMANCE IN ACCORDANCE WITH EN 13501-1:2007+A1:2009

Classification no. 2016-Efectis-R000229

Sponsor Avery Dennison

Graphics & Reflective Solutions

P.O. Box 28 2300 AA LEIDEN THE NETHERLANDS

Product name Avery Dennison® MPI[™] 8024 Wall Film EA Hi-Tack

Prepared by Efectis Nederland BV

Notified body no. 1234

Author(s) C.C.M. Steinhage B.Sc.

A.J. Lock

Project number ENL-15-001399

Date of issue March 2016

Number of pages 5

All rights reserved.

No part of this publication may be reproduced and/or published without the previous written consent of Efectis Nederland. Submitting the report for inspection to parties who have a direct interest is permitted.



In case this report was drafted on instructions, the rights and obligations of contracting parties are subject to either the Standard Conditions of Efectis Nederland or the relevant agreement concluded between the contracting parties.

© 2016 Efectis Nederland BV Page 1 / 5



INTRODUCTION

This classification report defines the classification assigned to Avery Dennison® MPI[™] 8024 Wall Film EA Hi-Tack in accordance with the procedures given in EN 13501-1:2007+A1:2009.

2. DETAILS OF CLASSIFIED PRODUCT

2.1 GENERAL

The product, **Avery Dennison® MPI™ 8024 Wall Film EA Hi-Tack**, is defined as a wall covering.

2.2 MANUFACTURER

Avery Dennison Graphics & Reflective Solutions P.O. Box 28 2300 AA LEIDEN THE NETHERLANDS

2.3 PRODUCT DESCRIPTION

According to the sponsor the product is composed of:

Film: 90 μm, matt, premium calendered high opacity vinyl

Adhesive: permanent clear acrylic based

• Backing paper: 126 g/m^2 , two sided PE coated StaflatTM paper See Appendix 'Product data sheet'.

In the end-use the product has a total thickness of approx. 90 μ m and a mass per unit area of approx. 210 g/m² (measured on the product).

3. REPORTS, RESULTS AND CRITERIA IN SUPPORT OF THIS CLASSIFICATION

3.1 REPORTS

Name of Laboratories	Name of sponsor	Report ref. no.	Test method
Efectis Nederland BV THE NETHERLANDS	Avery Dennison Graphics & Reflective Solutions THE NETHERLANDS	2016-Efectis-R000227 2016-Efectis-R000228	EN ISO 11925-2:2010 EN 13823:2014



3.2 TEST RESULTS

	Parameter		Results		
Test method and test number		Continuous parameter - mean (m)	Compliance with parameters		
EN ISO 11925-2					
surface flame impingement	Fs ≤150 mm		6	20	-
	Ignition of filter	paper	O	-	Compliant
Edge flame Impingement	Fs ≤150 mm		6	10	-
	Ignition of filter	paper	O	-	Compliant
EN 13823					
	FIGRA _{0.2MJ}	[W/s]		43	-
	FIGRA _{0.4MJ}	[W/s]		0	-
	THR _{600s}	[MJ]		0.7	-
	LFS < edge			-	Compliant
	SMOGRA	$[m^2/s^2]$	3	8.6	-
	TSP _{600s}	[m ²]		39	-
	Flaming debris - flaming ≤ 10 s - flaming > 10 s			-	Compliant Compliant

3.3 CLASSIFICATION CRITERIA

Fire classification of construction products and building elements Excluding floorings and linear pipe thermal insulation products							
Classification criteria							
Class Test method(s)	В	С	D				
EN ISO 11925-2 Exposure = 30 s	$F_s \le$ 150 mm within 60 s Ignition of the paper in EN ISO 11925-2 results in a d2 classification.						
EN 13823	$\begin{array}{l} FIGRA_{0.2 \text{ MJ}} \leq 120 \text{ W/s} \\ LFS < edge \text{ of specimen} \\ THR_{600s} \leq 7.5 \text{ MJ} \end{array}$	FIGRA _{0.4 MJ} \leq 250 W/s LFS $<$ edge of specimen THR _{600s} \leq 15 MJ	FIGRA _{0.4 MJ} ≤ 750 W/s				
Additional classification							
Smoke production	$s1 = SMOGRA \le 30 \text{ m}^2/\text{s}^2 \text{ and } TSP_{600s} \le 50 \text{ m}^2$; $s2 = SMOGRA \le 180 \text{ m}^2/\text{s}^2 \text{ and } TSP_{600s} \le 200 \text{ m}^2$; s3 = not s1 or s2						
Flaming Droplets/particles	d1 = no flaming drople	no flaming droplets/ particles persisting longer than 10 s in EN 13823 within 600 s;					



4. CLASSIFICATION AND FIELD OF APPLICATION

4.1 REFERENCE OF CLASSIFICATION

This classification has been carried out in accordance with clause 11 of EN 13501-1:2007+ A1:2009.

4.2 CLASSIFICATION

The product, Avery Dennison® MPI[™] 8024 Wall Film EA Hi-Tack, in relation to its reaction to fire behaviour is classified:

В

The additional classification in relation to smoke production is:

S¹

The additional classification in relation to flaming droplets / particles is:

d0

Reaction to fire classification: B - s1, d0

4.3 FIELD OF APPLICATION

This classification is valid for the following product parameters:

Thickness 90 mm

Surface density 210 g/m²

Other properties Opaque

This classification is valid for the following end use applications:

Substrate Non-combustible

(class A1 according to EN 13238:2010)

Air gap Including air gap

Methods and means of fixing Using adhesive of the product

Joints Vertical only

Other aspects of end use

conditions

Wall covering

4.4 DURATION OF THE VALIDITY OF THIS CLASSIFICATION REPORT

There are no limitations in time on the validity of this report.







5. LIMITATIONS

This classification document does not represent type approval or certification of the product.

C.C.M. Steinhage B.Sc.

Project leader reaction to fire

A.J. Lock

Project leader reaction to fire