



Neschen Coating GmbH
Hans-Neschen-Straße
31675 Bückeburg
Germany

Your message - reference

-

our reference

PW/0152

Gent

2022-01-26

Certification report 22/0152

1. Description of the product:

Product family	Decorative wallcovering made of PVC free coated non-woven
Total mass	170 g/m ²
Thickness	0.22 mm

2. Test results:

EN ISO 11925-2 (exposure=30s)	EN 13823
-------------------------------	----------

This report includes 2 pages and may only be reproduced in its entirety. The test results cover the received samples. Centexbel is not responsible for the representativeness of the samples.

Centexbel is a notified body N° 0493 for the European CPR (Construction Products Regulation) and for the European Directive related to Personal Protection Equipment.

CENTEXBEL • textile competence centre • www.centexbel.be

GENT • Technologiepark 7 • BE 9052 Gent • Belgium • phone +32 9 220 41 51 • fax +32 9 220 49 55 • gent@centexbel.be

VAT • BE 0459.218.289 • IBAN • BE 44 2100 4729 6545 • BIC • GEBABEBB

addressee

Neschen

our reference

PW/0152

Gent

2022-01-26

page

2

3. Conclusion:

Referring to the means of control and the test results, the before mentioned product group can be classified as follows according EN 13501-1:2018:

B – s1, d0

if glued to substrates having a Euroclass A2-s1,d0 or A1 which density is superior to 525kg/m³

Related commercial names to this product group

NE wallpaper L-UV smooth FR

The obtained classification is based on the next test reports

CREPIM: DO-21-3433\A-R1 d.d. 26-11-2021

Validity of the certificate

25-11-2026

Petra Wittevrongel

Product Certifier

